



ADDENDUM #4- EFFECTIVE October 20, 2026

This addendum covers questions sent by email on October 19, 2026.

ITEM #1

Question:

Fabricator Qualifications – Section 05 50 00, Paragraph 1.05

The specifications require an ICBO Approved Fabricator or AISC Certified Fabricator. Will a non-AISC-certified fabrication shop be permitted to perform the stainless-steel railing work utilizing qualified welders, compliant welding procedures, and third-party inspection as required?

Answer:

Yes.

ITEM #2

Question:

Welding Requirements – Section 05 50 00

Please confirm that AWS D1.6 governs the welding of the 316 stainless steel railing assemblies. Are project-specific welding procedure qualifications (PQRs) required, or will existing qualified welding procedures and welder qualifications be acceptable?

Answer:

AWS D1.6 governs and existing qualified welding procedures and welder qualifications are acceptable if they are not over 5 years old.

ITEM #3

Question:

Stainless Steel Finish – Section 05 50 00

Please clarify the required surface finish for the stainless-steel railings, including whether a #4 brushed finish, mill finish, or another finish is required. Please also confirm the finishing requirements for welded connections.

Answer:

#4 brushed finish or similar finish that is recommended for outdoor waterfront public park use.

ITEM #4

Question:

Bid form / Measurement & Payment: Specification Section 01 20 00 lists 12 bid items for measurement and payment; however, the bid form only provides for a lump sum bid item. Will the City provide a revised bid form to align with the measurement and payment requirements in Section 01 20 00?

Answer:

If there is only going to be 1 bid number, submit a schedule of values in your bid so that a breakdown may be reviewed.