ADDENDUM #5- EFFECTIVE October 20, 2026

This addendum covers questions sent by email on October 20, 2026.

ITEM #1

Question:
2.01 A 10 g. Polyethylene Tubs: Minimum wall thickness of 0.20 inch. 0.20 is a custom wall thickness with a cost increase. The manufacturer's typical is 0.15 inch. Is this acceptable?

Answer:
Yes, a 0.15 tub thickness is acceptable if it meets the rest of the requirements.

ITEM #2

Question:
The kayak dock appears to be a plastic structure. Will an aluminum-framed kayak launch station be accepted?

Answer:
Yes, an aluminum framed kayak launch float is acceptable if it provides similar accessibility and functionality and has plastic tub flotation.

City Council:
Mayor Mohamed Egal, Deputy Mayor Senayet Negusse
Caitlin Konya, Peter Kwon, James W. Lovell, Bedria Abdullahi, Joe Vinson

City Manager Jonathan Young
City Attorney Cindy Corsilles
City Clerk Kristina Gregg